

Schedule of Finish Hardware

For

Melmark

13325 South Point Blvd

Charlotte, NC 28273

Job # 356452



COOK & BOARDMAN

A DIVISION OF THE COOK & BOARDMAN GROUP, LLC

9347 D. Ducks Lane

Suite A • Charlotte, NC 28273 • Phone: 704-334-8683 • Fax: 704-334-9366

Architect/Designer
OSSA Studio

General Contractor
Swinerton Builders
2002 Clayton Road, 7th Floor
Concord, CA 94520
Phone: 925-602-6400 Fax:

Salesperson: Kevin Rogers
Email: kr Rogers@cookandboardman.com

Project Manager: Kevin Rogers
Email: kr Rogers@cookandboardman.com

Prepared by: Kirk Hargis

Submittal Date: February 10, 2023
Revised: April 4, 2023

Ossa Studio Revisions
6/8/2023



"AHC's employed"



"Chain of Custody Certified"

Plans, Specifications & Addenda

- Architect's Plans Dated: 01/10/23
- Specifications Dated: 10/11/22
- Addenda:

Notes & Comments

In the process of detailing the hardware for this project, we encountered conflicts with the hardware, as specified, as it relates to the contract documents. The following is a tabulated list of those problem areas, and the action we have taken. Please review the following, and approve the actions we have taken, or comment as to how we should proceed.

Opening #	Remark	Answer
Keyway	Advise Keyway	<i>No Preference, All Locks Keyed Alike</i>
710A	Specified NTT Trim Is Not Available For Use On Any Device Other Than Rim Exits. If NTT Is Required, We Suggest Changing (2) Concealed Vertical Rods To (2) Rim Exits With A Mullion. Please Advise.	<i>Passage Vertical Rods</i>
710B	Specified NTT Trim Is Not Available For Use On Any Device Other Than Rim Exits. If NTT Is Required, We Suggest Changing Mortise Exit Device To A Rim Exit Device. Please Advise.	<i>Passage Rim Device</i>
310B, 360B, 370B, 380B, 400A, 610A, 100A, 100B, 600A	We Have Put Openings That May Be Eliminated, Change Hands, and Aluminum Storefront On Hold Until We Receive Direction On How To Proceed.	
310B, 360B, 360B, 380B, 610A	Proceed with these.	
400A	Make this 4-0 x 8-0.	
100A, 100B, 600A	These are Storefront. I don't think they have any CB Scope?	Below For Additional Questions.

Hardware Schedule

HEADING #00 (SET #00)

Opening Description:

1 Other Door #KEYS

5 Construction key	CONSTRUCTION KEY		YA01
5 Master Keys	MASTER KEYS		YA01
2 Const. Control Key	YALE - CONTRUCTION CONTROL KEY		YA01
2 Control Key	CONTROL KEY		YA01

HEADING #A.1 (SET #A.1)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #111A	Eatery 110 from Storage 111		LHR
1 Single Door #471A	Storage 470 from Telecom 471		LHR
1 Single Door #521A	Classroom 10 520 from Storage 521		RHR
1 Single Door #541A	Classroom 12 540 from Storage 541		RHR
1 Single Door #711A	Gym 710 from Storage 711		LHR

15 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
5 Touchscreen Cylindrical Lock	AU NTB622-NR 1210 497 694 TEMPORARY CORE	626	YA
5 LFIC Core	1210 MK	626	YA
5 Wall Stop	409	US32D	RO
15 Door Silencer	608-RKW	GREY	RO

Note: No Stop Specified. Template Closer To 120° And Adjust Backcheck To Control Door. Remove Closer, Add Wall Stop per Approval.

HEADING #A.2 (SET #A.2)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #220A	Corridor 200 to Admin / IT 220		RH
1 Single Door #230A	Corridor 201 to Office 230		LH
1 Single Door #240A	Corridor 201 to Computer Carrels 240		RH
1 Single Door #250A	Corridor 201 to Office 250		LH
1 Single Door #280A	Staff Break 260 to Office 280		LH
1 Single Door #281A	Office 280 to Storage 281		LH
1 Single Door #311A	Classroom 01 310 to Storage 311		LH
1 Single Door #312A	Corridor 400 to Observation 312		LH
1 Single Door #331A	Classroom 03 330 to Storage 331		LH
1 Single Door #332A	Corridor 400 to Observation 332		LH
1 Single Door #351A	Classroom 05 350 to Storage 351		LH
1 Single Door #352A	Corridor 400 to Observation 352		LH
1 Single Door #371A	Classroom 07 370 to Storage 371		LH
1 Single Door #372A	Corridor to Observation 372		LH
1 Single Door #410A	Corridor 400 to Professional Development 410		RH
1 Single Door #420A	Corridor 400 to Nurse 420		LH
1 Single Door #440A	Corridor 400 to PM Office 440		RH
1 Single Door #450A	Corridor 400 to PD Office 450		LH
1 Single Door #460A	Corridor 404 to Office 460		RH
1 Single Door #470A	Corridor 404 to Storage 470		LH
1 Single Door #512A	Corridor 404 to Observation 512		RH
1 Single Door #532A	Corridor 404 to Observation 532		RH
1 Single Door #610A	East Lobby 600 to Office 610		LH
1 Single Door #620A	Corridor to Occupational Therapy 620		RH
1 Single Door #630A	Corridor to OT/PT/Speech Office 630		LH
75 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
25 Touchscreen Cylindrical Lock	AU NTB622-NR 1210 497 694 TEMPORARY CORE	626	YA
25 LFIC Core	1210 MK	626	YA
25 Wall Stop	409	US32D	RO
75 Door Silencer	608-RKW	GREY	RO

Proceed

610A - Opening On Hold. May Change Hand per Approval.

Proceed

HEADING #A.2-1 (SET #A.2)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #321A	Classroom 02 320 from Storage 321	LHR	
1 Single Door #341A	Classroom 04 340 from Storage 341	LHR	
1 Single Door #361A	Classroom 06 360 from Storage 361	LHR	
1 Single Door #381A	Classroom 08 380 from Storage 381	LHR	
1 Single Door #430A	Corridor 400 to Storage 430	RH	
1 Single Door #511A	Classroom 09 510 from Storage 511	LHR	
1 Single Door #531A	Classroom 11 530 from Storage 531	LHR	
1 Single Door #712A	Gym 710 to Storage 712	RH	
24 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
8 Touchscreen Cylindrical Lock	AU NTB622-NR 1210 497 694 TEMPORARY CORE	626	YA
8 LFIC Core	1210 MK	626	YA
8 Dome Stop	440	US26D	RO
24 Door Silencer	608-RKW	GREY	RO

Note: Changed Specified Wall Stop To Dome Stop Due To Handle Not Intersecting Wall. Please Confirm This Is Acceptable. Yes per Approval.
Remove closer per Approval.
430A - Heading A.3 to A.2-1 per Approval.
321A, 341A, 361A, 381A, 511A, 531A - Heading A.5 to A2.1 per Approval.

HEADING #A.6 (SET #A.6)

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Pair Doors #482A	Corridor 400 from Storage 482	LHRA	
1 Pair Doors #492A	Corridor 404 from Storage 492	RHRA	
12 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
2 Combination Flush Bolt	2845	US32D	RO
2 Dust Proof Strike	570	US26D	RO
2 Touchscreen Cylindrical Lock	AU NTB622-NR 1210 497 694 TEMPORARY CORE	626	YA
2 LFIC Core	1210 MK	626	YA
2 Wall Stop	409	US32D	RO
4 Door Silencer	Note: LHR Leaf @ 482A, RHR Leaf @ 492A 608-RKW	GREY	RO

Note: Only 1 Leaf Of Opening Will Swing To Wall. Inactive Leaf To Open Against Corner Guard per Approval.

HEADING #A.7 (SET #A.7)

Opening Description: 2' 8" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #481A	Corridor 400 from Janitor 481		RHR
1 Single Door #491A	Corridor 404 from Storage 491		LHR
6 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
2 Touchscreen Cylindrical Lock	AU NTB622-NR 1210 497 694 TEMPORARY CORE	626	YA
2 LFIC Core	1210 MK	626	YA
2 Wall Stop	409	US32D	RO
2 Smoke Seal	S88 BL 17'		PE

HEADING #G.1 (SET #G.1)

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Pair Doors #710A	East Lobby 600 from Gym 710		RHRA
6 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
1 Exit Device	7160 x AU548F LBR	626, 630	YA
1 Exit Device	7160 LBR	630	YA
1 Closer	PR3311	LH 689	YA
	Note: Mount Closer On Push Side Of Door		
1 Closer	PR3311	RH 689	YA
	Note: Mount Closer On Push Side Of Door		
2 Door Silencer	608-RKW	GREY	RO

Note: Specified NTT Trim Is Not Available For Use On Any Device Other Than Rim Exits. If NTT Is Required, We Suggest Changing (2) Concealed Vertical Rods To (2) Rim Exits With A Mullion. Please Advise. Remove NTT Trim, Add 548 Passage Trim per Approval.

HEADING #G.2 (SET #G.2)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #710B	Corridor 404 from Gym 710		LHR
3 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
1 Exit Device	7100 x AU548F	626, 630	YA
1 Closer	PR3311	RH 689	YA
	Note: Mount Closer On Push Side Of Door		
1 Wall Stop	409	US32D	RO
3 Door Silencer	608-RKW	GREY	RO

Note: Specified NTT Trim Is Not Available For Use On Any Device Other Than Rim Exits. If NTT Is Required, We Suggest Changing Mortise Exit Device To A Rim Exit Device. Please Advise. Remove NTT Trim and add Rim Device With 548 Passage Trim per Approval

HEADING #P.2 (SET #P.2)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #210A	Corridor 200 to Conference 210	RH
1 Single Door #310A	Corridor 400 to Classroom 01 310	LH
1 Single Door #310B	Corridor 400 to Classroom 01 310	RH
1 Single Door #320A	Corridor 400 to Classroom 02 320	RH
1 Single Door #330A	Corridor 400 to Classroom 03 330	LH
1 Single Door #340A	Corridor 400 to Classroom 04 340	RH
1 Single Door #350A	Corridor 400 to Classroom 05 350	LH
1 Single Door #360A	Corridor 400 to Classroom 06 360	RH
1 Single Door #360B	Corridor to Classroom 06 360	LH
1 Single Door #370A	Corridor to Classroom 07 370	LH
1 Single Door #370B	Corridor to Classroom 07 370	RH
1 Single Door #380A	Corridor to Classroom 08 380	RH
1 Single Door #510A	Corridor 404 to Classroom 09 510	RH
1 Single Door #520A	Corridor 404 to Classroom 10 520	LH
1 Single Door #530A	Corridor 404 to Classroom 11 530	RH
1 Single Door #540A	Corridor 404 to Classroom 12 540	LH

48 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
16 Passage	AU 5401LN	626	YA
16 Wall Stop	409	US32D	RO
48 Door Silencer	608-RKW	GREY	RO

Note: 310A, 310B, 320A, 320B, 330A, 330B, 340A, 340B, 370A, 370B, 380A, 510A, 520A, 530A, 540A - HW Set A.2 to P.2 per Approval.

400A to be 4-0 x 8-0.

310B, 360B, 370B, 380B, 400A - Openings On Hold. Openings May Be Eliminated per Approval.

Proceed

HEADING #P.2-1 (SET #P.2)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #270A	Corridor 200 to Conference 270	LH
1 Single Door #380B	Corridor to Classroom 08 380	LH

6 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
2 Passage	AU 5401LN	626	YA
2 Dome Stop	440	US26D	RO
6 Door Silencer	608-RKW	GREY	RO

Note: Changed Specified Wall Stop To Dome Stop Due To Handle Intersecting Window When Open. Please Confirm This Is Acceptable. Yes per Approval.
380B - HW Set A.2 to P.2 per Approval.

HEADING #P.3 (SET #P.3)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #421A	Nurse 420 from Shower 421		RHR
3 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
1 Privacy Set	AU YPL02	626	YA
1 Closer	3331	689	YA
	Note: Mount Closer On Push Side Of Door		
3 Door Silencer	608-RKW	GREY	RO
1 Coat Hook	RM829	US32D	RO
	Note: Mount Centered On Door 48" AFF.		

Note: 421A - Confirm Hardware Set T.1 Is Acceptable. Specified Hardware Set P.3 Does Not Exist On Plan A00.05. Same As T.1, Add Stop Arm Closer per Approval.

HEADING #T.0 (SET #T.0)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #480A	Corridor 402 to Boys 480		LH
1 Single Door #490A	Corridor 402 to Girls 490		RH
6 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
2 Pull Plate Set	110 X 73C/73CL	US32D	RO
2 Closer	3301	689	YA
	Note: Mount Closer On Pull Side Of Door		
2 Protection Plate	K1050 10" x 34"	US32D	RO
2 Protection Plate	K1050 4" x 35"	US32D	RO
2 Wall Stop	409	US32D	RO
6 Door Silencer	608-RKW	GREY	RO

HEADING #T.0-1 (SET #T.0)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #400A	Corridor 400 to Corridor		RH
4 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
1 Pull Plate Set	110 X 73C/73CL	US32D	RO
1 Closer	3301	689	YA
	Note: Mount Closer On Pull Side Of Door		
1 Protection Plate	K1050 10" x 46"	US32D	RO
1 Protection Plate	K1050 4" x 47"	US32D	RO
1 Automatic Door Holder	490 -RKW	US26D	RO
w/ Stop			
4 Door Silencer	608-RKW	GREY	RO

Note: 400A - Door Handle May Not Hit Wall Stop. Advise If A Floor Stop Should Be Added In Lieu Of Wall Stop. Yes, Make Hold Open Type (Ansi) L01301 per Approval. **Make this a wall stop/holder.**

400A - Opening On Hold. May Be Eliminated per Approval. **We moved this door back against the wall.**

HEADING #T.1 (SET #T.1)

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD x HM

1 Single Door #290A	Corridor 401 to Toilet 290	LH
1 Single Door #291A	Corridor 401 to Toilet 291	LH
1 Single Door #292A	Corridor 401 to Toilet 292	LH
1 Single Door #293A	Corridor 401 to Toilet 293	LH
1 Single Door #294A	Corridor 401 to Toilet 294	LH
1 Single Door #295A	Corridor 401 to Toilet 295	LH

18 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
6 Privacy Set	AU YPL02	626	YA
6 Closer	3301	689	YA
	Note: Mount Closer On Pull Side Of Door		
18 Door Silencer	608-RKW	GREY	RO
6 Dome Stop	440	US26D	RO
6 Coat Hook	RM829	US32D	RO
	Note: Mount Centered On Door 48" AFF.		

Note: 290A, 291A, 292A, 293A, 294A, 295A - Confirm Paper Towel/Waste Receptacle Will Be Installed Not To Interfere With Door Opening To Wall Stop, Or Advise If Floor Stop Or Overhead Stop Should Be Added. Floor Stop per Approval. Cal-Royal Indicator Lock to YPL Series, 806 to RM829 Coat Hook per Approval.

HEADING #T.2 (SET #T.2)

Opening Description: 2' 8" x 4' 10" x 1 3/4 x WD x HM

1 Single Door #480B	Boys 480 to Toilet	RH
1 Single Door #480C	Boys 480 to Toilet	RH
1 Single Door #490B	Girls 490 to Toilet	LH
1 Single Door #490C	Girls 490 to Toilet	LH
1 Single Door #490D	Girls 490 to Toilet	LH
1 Single Door #490E	Girls 490 to Toilet	LH

12 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
6 Privacy Set	AU YPL02	626	YA
6 Wall Stop	409	US32D	RO
18 Door Silencer	608CA	CLEAR	RO
6 Coat Hook	RM829	US32D	RO
	Note: Mount Centered On Door 48" AFF.		

Note: Stick On Silencers Scheduled Due To Door Length.

Cal-Royal Indicator Lock to YPL Series, 806 to RM829 Coat Hook per Approval.

HEADING #T.2-1 (SET #T.2)

Opening Description: 3' 0" x 4' 10" x 1 3/4 x WD x HM

1 Single Door #480E	Boys 480 from Toilet		RHR
2 Hinges	MPB79 4 1/2 x 4 1/2	26D	MC
1 Privacy Set	AU YPL02	626	YA
1 Door Stop	RM875	US32D	RO
3 Door Silencer	608CA	CLEAR	RO
1 Coat Hook	RM829	US32D	RO

Note: Mount Centered On Door 48" AFF.

Note: Door Swings Out. Specified Wall Stop Will Not Work. Advise If A Hinge Pin Stop Should Be Added As A Dome Stop Or Overhead Stop Will Not Work Either. Provide RM875 And Mount On Door 480F per Approval.

Cal-Royal Indicator Lock to YPL Series, 806 to RM829 Coat Hook per Approval.

Leaving 2 Spring Hinges Unless Told Otherwise, As It Is Our Experience That 2 Spring Hinges Work Better Than Just One. Installer Does Not Have To Power Spring Hinges To Maximum Power.

Stick On Silencers Scheduled Due To Door Length.

HEADING #T.3 (SET #T.3)

Opening Description: 3' 0" x 4' 10" x 1 3/4 x WD x HM

1 Single Door #480F	Boys 480 to Toilet		RH
1 Single Door #490F	Girls 490 to Toilet		LH
4 Spring Hinge	MPS60 4 1/2 X 4 1/2	26D	MC
2 Privacy Set	AU YPL02	626	YA
2 Wall Stop	409	US32D	RO
6 Door Silencer	608CA	CLEAR	RO
2 Coat Hook	RM829	US32D	RO

Note: Mount Centered On Door 48" AFF.

Note: We Have Scheduled Spring Hinges In Lieu Of Closer, And Stick On Silencers Due To Door Not Being Full Length.

Cal-Royal Indicator Lock to YPL Series, 806 to RM829 Coat Hook per Approval.

Leaving 2 Spring Hinges Unless Told Otherwise, As It Is Our Experience That 2 Spring Hinges Work Better Than Just One. Installer Does Not Have To Power Spring Hinges To Maximum Power.

HEADING #X.1 (SET #X.1)

Opening Description: 3' 0" x 7' 0" x EX x EX

1 Single Door #100A		Exterior from Vestibule		RHR	
1 Single Door #600A		Exterior from East Lobby 600		LHR	
1 Exit Device	7130-K5 2196 TEMPORARY CORE		LHR	BSP	YA
1 Exit Device	7130-K5 2196 TEMPORARY CORE		RHR	BSP	YA
2 Electric Strike	1006			BLK	HS
2 Faceplate				BSP	HS
2 LFIC Core				626	YA
2 Offset Door Pull	TBF156 TYPE 1 FASTENING			BSP	RO
2 Smoke Seal	S88 BL 17'				PE

I believe this still needs to be coordinated with the glass contractor.

Note: Confirm Existing Door Will Accept Scheduled Hardware. Including Being Prepped For A Mortise Exit Device Which Requires A Minimum 4-1/2" Stile. 3-1/2" Tube per Approval. Openings On HOLD Until Field Verification Or A1 Glass Advises What Is Required. Hardware As Currently Scheduled Will NOT Work Due To Size Of Storefront Stile. We Would Recommend A 7200 Rim Device For A Narrow Stile With A HES 9600 Surface Mount Electric Strike.

Balance Of Hardware Is Existing To Remain.

HEADING #X.2 (SET #X.2)

Opening Description: 3' 0" x 7' 0" x EX x EX

1 Single Door #100B		Vestibule from West Lobby 100		RHR	
1 Push/Pull Bar	11047 33" T3 Mounting			BSP	RO
1 Concealed Closer				693	DM
1 Smoke Seal					PE

I believe this still needs to be coordinated with the glass contractor.

Note: Confirm Existing Door Will Accept Scheduled Hardware. Concealed Closer Is For Aluminum Opening On Butt Hinges. New Assembly, Coordinate With A1 Glass. Openings On HOLD Until Field Verification Or A1 Glass Advises What Is Required.

Balance Of Hardware Is Existing To Remain.

HEADING #X.3 (SET #X.3)

Opening Description: 3' 0" x 7' 0" x EX x EX

1 Single Door #101A		Vestibule from Sprinkler 101		RHR	
1 Lockset	AU 5405LN 1210 TEMPORARY CORE			626	YA
1 LFIC Core	1210 MK			626	YA

Note: Add 5405 per Approval.

Balance Of Hardware Is Existing To Remain.

HEADING #X.3.1 (SET #X.3)

Opening Description: 3' 0" x 7' 0" x EX x EX

1 Single Door #431A		Storage 430 from Electrical 431	RHR
1 Cylindrical Lock	AU NTB622-NR 1210 497 694 TEMPORARY CORE	626	YA
1 LFIC Core	1210 MK	626	YA

Note: Add NTB622 Keypad Lock per Approval.

Balance of Hardware Is Existing To Remain.

HEADING #CO (SET #CO)

Opening Description: 5' 0" x 7' 0" x HM C-Opg

1 Single Door #110A	West Lobby 100 to/from Eatery 110
1 Single Door #110B	West Lobby 100 to/from Eatery 110
1 Single Door #282A	Corridor 400 to/from Print/Copy/Coffee 282

Note: Cased Open, No Hardware Required.

HEADING #BL (SET #BL)

Opening Description: 12' 2" x 4' 0" x HMF

1 Other Door #BL-270.2	Corridor 201 to Conference 270
------------------------	--------------------------------

Note: Borrowed Lite, No Hardware Required.

HEADING #BL-1 (SET #BL)

Opening Description: 14' 6" x 4' 0" x HMF

1 Other Door #BL-270.1	Corridor 200 to Conference 270
------------------------	--------------------------------

Note: Borrowed Lite, No Hardware Required.

HEADING #BL-2 (SET #BL)

Opening Description: 2' 8" x 4' 0" x HMF

1 Other Door #BL-610	East Lobby 600 to Office 610
----------------------	------------------------------

Note: Borrowed Lite, No Hardware Required.

HEADING #BL-3 (SET #BL)

Opening Description: 3' 8" x 3' 8" x HMF

- | | |
|----------------------|---|
| 1 Other Door #BL-210 | Corridor 200 to/from Conference 210 |
| 1 Other Door #BL-220 | Corridor 200 to/from Admin / IT 220 |
| 1 Other Door #BL-240 | Corridor 201 to/from Computer
Carrels 240 |
| 1 Other Door #BL-250 | Corridor 201 to/from Office 250 |
| 1 Other Door #BL-280 | Corridor 201 to/from Office 280 |
| 1 Other Door #BL-310 | Classroom 01 310 to Observation 312 |
| 1 Other Door #BL-320 | Classroom 02 320 to Observation 312 |
| 1 Other Door #BL-330 | Classroom 03 330 to Observation 332 |
| 1 Other Door #BL-340 | Classroom 04 340 to Observation 332 |
| 1 Other Door #BL-350 | Classroom 05 350 to Observation 352 |
| 1 Other Door #BL-360 | Classroom 06 360 to Observation 352 |
| 1 Other Door #BL-370 | Classroom 07 370 to Observation 372 |
| 1 Other Door #BL-380 | Classroom 08 380 to Observation 372 |
| 1 Other Door #BL-410 | Corridor 400 to Professional
Development 410 |
| 1 Other Door #BL-420 | Corridor 400 to Nurse 420 |
| 1 Other Door #BL-440 | Corridor 400 to PM Office 440 |
| 1 Other Door #BL-450 | Corridor 400 to PM Office 440 |
| 1 Other Door #BL-460 | Corridor 404 to Office 460 |
| 1 Other Door #BL-510 | Classroom 09 510 to Observation 512 |
| 1 Other Door #BL-520 | Classroom 10 520 to Observation 512 |
| 1 Other Door #BL-530 | Classroom 11 530 to Observation 532 |
| 1 Other Door #BL-540 | Classroom 12 540 to Observation 532 |
| 1 Other Door #BL-620 | Corridor to Occupational Therapy
620 |
| 1 Other Door #BL-630 | Corridor to OT/PT/Speech Office 630 |

Note: Borrowed Lite, No Hardware Required.