

Schedule of Finish Hardware

for
Charleston Place Permit Package 3
205 Meeting Street
Charleston, SC 29401
Job # 364458



COOK & BOARDMAN

A DIVISION OF THE COOK & BOARDMAN GROUP, LLC

7355 Cross County Road
Building # 1 • North Charleston, SC 29418 • Phone: 843-302-0101 • Fax: 843-302-0105

Architect/Designer
Cooper Carry

General Contractor
Choate Construction
Email: ap@choateco.com
Mt. Pleasant, SC 29464
Phone: (843) 284-9047 Fax: (843) 284-9048

Salesperson: Chris Shaffer
Email:
Project Manager: Chris Shaffer
Email:
Prepared by: Carrie Powell
Submittal Date: August 13, 2024

RECORD OF SUBMITTALS		
	SUBMITTED	RETURNED
1 ST		
2 ND		
3 RD		
4 TH		



"AHC's employed"



"Chain of Custody Certified"

Contract Information Request

Project: Charleston Place Permit Package 3
Job #: 364458

To help us process the above project in a timely manner,
please complete the following information as soon as possible.

1. Required Delivery Dates:

- Finish Hardware _____
- Phasing Schedule Provided By: MM/DD/YY

2. Specific Keying Instructions:

<input type="checkbox"/> New System		<input type="checkbox"/> Key Schedule Provided By: MM/DD/YY
<input type="checkbox"/> Existing System		<input type="checkbox"/> Key Meeting Requested
Manufacturer:	Structure:	

3. Standard Manufacturers Lead Times:

Non-Keyed Mechanical Hardware – six to eight weeks (after approval of schedule)
Electronic Hardware – fourteen to sixteen weeks (after approval of schedule)
Keyed Hardware – ten to twelve weeks (after approved key schedule)

**Edit as necessary and
delete this note.**


Your project is on HOLD until we receive the requested information. Any delays resulting from the lack of this information will be your responsibility.

Signed _____

Dated _____

Clarifications

1. All hardware for aluminum doors by others (except cylinders where required).
2. All wiring by others.
3. Auto operators and all related accessories by others.
4. Card readers by others.
5. Door position switches by others.



**Edit as necessary and
delete this note.**

Request for Information

General Requests for Information

1. Please verify all hardware sets.
2. Verify cylinder requirements.
3. Verify hardware finishes.

Edit as necessary and delete this note.

Section Specific Requests for Information

Section/Opening	Remark	Answer

Hardware Schedule

Heading #01

1 Other Door #1026C

Loading Dock to/from BOH
Corr 1026

1 Construction Core	7190224		BE
1 Rim Cylinder	12E-72 PATD CORMAX PATENTED KEYING	626	BE

Note: Balance of hardware by storefront supplier.

Charleston Place Permit Package 3
364458

Heading #02

1 Single Door #1028	Receiving 1030 from Lost/Found 1028	RH
1 Single Door #1045	Loading Dock to Elev Machine 1045	LH
1 Single Door #2029	Walk-in 3036 from Storage 2029	LHR

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D2 x HM Type 01
3' 0" x 7' 0" x 1¾" x HM Type D2 x HM Type 03

9 Butt Hinge	FBB179 4.5" x 4.5"		26D	ST
1 Lockset	45H-7D15H PATD CORMAX PATENTED KEYING	LHR	626	BE
1 Lockset	45H-7D15H PATD CORMAX PATENTED KEYING	LH	626	BE
1 Lockset	45H-7D15H PATD CORMAX PATENTED KEYING	RH	626	BE
3 Construction Core	7190224			BE
3 Closer	EHD9016 AF90		689	BE
Note: SNB				
3 Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		630	TR
9 Silencer	1229A		GREY	TR

Charleston Place Permit Package 3
364458

Heading #02-1

1 Single Door #3019E

Corr 3019 from Unknown
Existing

LHR

Opening Description: 4' 0" x 7' 0" x 1¾" x HM Type D2 x HM Type 01

3	Butt Hinge	FBB179 4.5" x 4.5" NRP		26D	ST
1	Lockset	45H-7D15H PATD CORMAX PATENTED KEYING	LHR	626	BE
1	Construction Core	7190224			BE
1	Closer	EHD9016 AF90		689	BE
	Note: SNB				
1	Kick Plate	K0050 10" x 46" B4E-HEAVY-KP CSK		630	TR
3	Silencer	1229A		GREY	TR

Charleston Place Permit Package 3
364458

Heading #03

1 Single Door #1029	BOH Corr 1026 to Dir Sec Office 1029	RH
1 Single Door #1042	Engineering 1040 to Office 1042	LH
1 Single Door #2028	Bnqt Kitchen 2025 to Banquet Ofc 2028	LH

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D4 TO x HM Type 01
3' 0" x 7' 0" x 1¾" x HM Type D9 TO x HM Type 01
3' 0" x 7' 0" x 1¾" x HM Type D9 x HM Type 03

9 Butt Hinge	FBB179 4.5" x 4.5"		26D	ST
1 Lockset	45H-7AB15H PATD CORMAX PATENTED KEYING	RH	626	BE
2 Lockset	45H-7AB15H PATD CORMAX PATENTED KEYING	LH	626	BE
3 Construction Core	7190224			BE
3 Wall Bumper	1270WV		630	TR
9 Silencer	1229A		GREY	TR

Charleston Place Permit Package 3
364458

Heading #03-1

1 Single Door #2027

Bnqt Kitchen 2025 to Dir
Banquet 2027

RH

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D4 TO x HM Type 01

3	Butt Hinge	FBB179 4.5" x 4.5"		26D	ST
1	Lockset	45H-7AB15H PATD CORMAX PATENTED KEYING	RH	626	BE
1	Construction Core	7190224			BE
1	Wall Bumper	1270WV		630	TR
3	Silencer	1229A		GREY	TR

Charleston Place Permit Package 3
364458

Heading #04

1 Pair Doors #1031	BOH Corr 1026 to Dry Storage 1031	RHA
1 Pair Doors #2026B	Corr 2026 to Storage 2026B	RHA
1 Pair Doors #1077	BOH Corr 1026 to Dry Storage 1031	RHA

Opening Description: 2 - 3' 0" x 7' 0" x 1¾" x HM Type D2 x HM Type 01
2 - 3' 0" x 7' 0" x 1¾" x HM Type D3 x HM Type 04

18 Butt Hinge	FBB179 4.5" x 4.5" NRP	26D	ST
6 Manual Flushbolt	3917-12	626	TR
3 Lockset	45H-7D15H PATD CORMAX PATENTED KEYING	RH 626	BE
3 Construction Core	7190224		BE
6 Kick Plate	K0050 10" x 35" B4E-HEAVY-KP CSK	630	TR
6 Wall Bumper	1270WV	630	TR
6 Silencer	1229A	GREY	TR

Heading #06

1 Single Door #1034A

BOH Corr 1026 from Empl
Pantry 1036

LHR

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D2 x HM Type 03

3	Butt Hinge	FBB179 4.5" x 4.5" NRP		26D	ST
1	Exit Device	3RO 2108 X 4908A 36"	LHR	630	PR
1	Construction Core	7190224			BE
1	Rim Cylinder	12E-72 PATD CORMAX PATENTED KEYING		626	BE
1	Closer	EHD9016 SDS90		689	BE
1	Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		630	TR
1	Wall Bumper	1270WV		630	TR
3	Silencer	1229A		GREY	TR

Note: (Specified FL suffix on exit device is for a fire rated door. This is not needed as these doors are not fire rated).

Heading #06-1

1 Single Door #1034C

BOH Corr 1026 from Empl
Dining 1034

LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD Type D7 x HM Type 01

3	Butt Hinge	FBB179 4.5" x 4.5" NRP		26D	ST
1	Exit Device	3RO 2108 X 4908A 36"	LHR	630	PR
1	Construction Core	7190224			BE
1	Rim Cylinder	12E-72 PATD CORMAX PATENTED KEYING		626	BE
1	Closer	EHD9016 SDS90		689	BE
1	Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		630	TR
1	Wall Bumper	1270WV		630	TR
3	Silencer	1229A		GREY	TR

Note: (Specified FL suffix on exit device is for a fire rated door. This is not needed as these doors are not fire rated).

Charleston Place Permit Package 3
364458

Heading #07

1 Pair Doors #1034B

BOH Corr 1026 from Empl
Dining 1034

LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD Type D8 x HM Type 01

6	Butt Hinge	FBB179 4.5" x 4.5"		26D	ST
1	Exit Device	3RO 2214 X 4914A 36" 7'0" LBR	LHR	606	PR
1	Exit Device	3RO 2214 X 4914A 36" 7'0" LBR	RHR	606	PR
2	Closer	EHD9016 SDS90		689	BE
2	Kick Plate	K0050 10" x 35" B4E-HEAVY-KP CSK		630	TR
2	Silencer	1229A		GREY	TR

Note: Confirm trim style A (not B) was intended at this set as all other trim on project is specified as A.

Charleston Place Permit Package 3
364458

Heading #08

- 1 Single Door #1034D BOH Corr 1026 from Emply RHR
Dining 1034
- 1 Single Door #1034E BOH Corr 1026 from Emply RHR
Dining 1034

Opening Description: 1' 10" x 7' 0" x 1¾" x HM Type D2 x HM Type 03

6 Butt Hinge	FBB179 4.5" x 4.5" NRP		26D	ST
2 Lockset	45H-7D15H PATD CORMAX PATENTED	RHR	626	BE
	KEYING			
2 Construction Core	7190224			BE
2 Kick Plate	K0050 10" x 20" B4E-HEAVY-KP CSK		630	TR
2 Kick Plate	K0050 10" x 21" B4E-HEAVY-KP CSK		630	TR
2 Wall Bumper	1270WV		630	TR
6 Silencer	1229A		GREY	TR

Charleston Place Permit Package 3
364458

Heading #08-1

1 Single Door #2025B

Corr 2026 from Bnqt Kitchen
2025

RHR

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D4 TO x HM Type 01

3	Butt Hinge	FBB179 4.5" x 4.5" NRP		26D	ST
1	Lockset	45H-7D15H PATD CORMAX PATENTED KEYING	RHR	626	BE
1	Construction Core	7190224			BE
1	Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		630	TR
1	Kick Plate	K0050 10" x 35" B4E-HEAVY-KP CSK		630	TR
1	Wall Bumper	1270WV		630	TR
3	Silencer	1229A		GREY	TR

Charleston Place Permit Package 3
364458

Heading #10

1 Single Door #1046

Loading Dock to Smoking
1046

LH

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D2 x HM Type 01 TO 3

3	Butt Hinge	FBB179 4.5" x 4.5"		26D	ST
1	Passage Set	45H-0N15H	LH	626	BE
1	Closer	EHD9016 AF90		689	BE
	Note: SNB				
1	Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		630	TR
3	Silencer	1229A		GREY	TR

Charleston Place Permit Package 3
364458

Heading #11

1 Pair Doors #2004C	Mezzanine from Guestroom Corr	LHRA
1 Pair Doors #2050	Corr 2050 from Meeting Corr	LHRA

Opening Description: 3' 0", 1' 11" x 7' 3" x 1 3/4 x WD Type D13 TO x HM Type 02 x 45 Min
3' 0", 1' 11" x 7' 3" x 1 3/4 x WD Type D6 TO x HM Type 01 x 45 Min

6 Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
6 Butt Hinge	2060R 4.5" x 4.5"		4	ST
2 Exit Device	3RO FL 2214 X 4914A 36" 8'0" LBR SNB (4)	LHR	606	PR
2 Exit Device	3RO FL 2214 X 4914A 36" 8'0" LBR SNB (4)	RHR	606	PR
2 Electromagnetic Door Holder	2100		S2	AB
2 Coordinator	3094D		BLACK	TR
4 Closer	EHD9016 AF90		606	BE
Note: SNB, MC not an option				
2 Gasketing	5050 B-25 25'			NA

Note: Closer on active leaf only/Spring hinges on inactive leaf.

Heading #12

1 Single Door #2017

Vestibule 2017 to/from BOH
Corr 2018

DA

Opening Description: 3' 0" x 7' 0" x Type D5 x HM C-Opg Type 01-CO

Note: All hardware by Eliason door manufacturer.

Heading #12-1

1 Pair Doors #2025A

BOH Corr 2018 to/from Bnqt
Kitchen 2025

DAP

Opening Description: 2 - 3' 0" x 7' 0" x Type D5 x HM C-Opg Type 02-CO

Note: All hardware by Eliason door manufacturer.

Heading #13

1 Single Door #2022B

Storage 2022 from Elec/IDF
2022B

RHR

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D2 x HM Type 01

3	Butt Hinge	FBB179 4.5" x 4.5" NRP		26D	ST
1	Exit Device	3RO 2103 X 4903A 36" SNB (2)	RHR	630	PR
1	Construction Core	7190224			BE
1	Rim Cylinder	12E-72 PATD CORMAX PATENTED KEYING		626	BE
1	Closer	EHD9016 SDS90		689	BE
1	Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		630	TR
1	Gasketing	5050 C-17 17'			NA

Heading #14

1 Pair Doors #2024

BOH Corr 2018 from Elev.
Lobby 2024

LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1¾" x HM Type D5 TO D x HM Type 02

6 Butt Hinge	FBB179 4.5" x 4.5"	26D	ST
2 Push/Pull Plate	1894-4	630	TR
2 Closer	EHD9016 SDS90	689	BE
2 Kick Plate	K0050 10" x 35" B4E-HEAVY-KP CSK	630	TR
2 Wall Bumper	1270WV	630	TR
2 Silencer	1229A	GREY	TR

Charleston Place Permit Package 3
364458

Heading #15

1 Single Door #2053A	Meeting Corr to Men 2053	RH
1 Single Door #2055A	Meeting Corr to Women 2055	LH

Opening Description: 3' 0" x 6' 10" x 1 3/4 x WD Type D1 x HMF Type 01

6 Butt Hinge	FBB179 4.5" x 4.5"		26	ST
1 Deadlock	48H-7R PATD CORMAX PATENTED KEYING	RH	606	BE
1 Deadlock	48H-7R PATD CORMAX PATENTED KEYING	LH	606	BE
2 Door Pull-Frank Allart	1916B BTB MTG		PN	VA01
6 Silencer	1229A		GREY	TR
1 Mortise Cylinder	1EA-6A4 RP2		606	BE
Openings/Qty: 1@2055A				
2 Mortise Cylinder	1EA-6A4 RP2		625	BE
2 Closer	ITS 9625 BRKTMD		606	DM
1 Kick Plate	K0050 8" x 34" B4E-HEAVY-KP CSK		606	TR
Openings/Qty: 1@2053A				
2 Door Pull-Frank Allart	1916B BTB MTG		SB.	VA01

Note: Verify hinge finish we have scheduled (bright chrome). The specified manufacturer does not offer a 645 (bright nickel) finish or any nickel finishes.

Heading #15-1

1 Single Door #2032A

Prefunction 2034 to Men
2032

RH

Opening Description: 3' 0" x 8' 0" x 1 3/4 x WD Type D1 x HM Type 01

4	Butt Hinge	FBB179 4.5" x 4.5"		26	ST
1	Deadlock	48H-7R PATD CORMAX PATENTED KEYING	RH	606	BE
1	Door Pull-Frank Allart	1916B BTB MTG		PN	VA01
3	Silencer	1229A		GREY	TR
1	Mortise Cylinder	1EA-6A4 RP2		625	BE
1	Closer	ITS 9625 BRKTMD		606	DM
1	Kick Plate	K0050 8" x 34" B4E-HEAVY-KP CSK		606	TR
1	Door Pull-Frank Allart	1916B BTB MTG		SB.	VA01

Note: Verify hinge finish we have scheduled (bright chrome). The specified manufacturer does not offer a 645 (bright nickel) finish or any nickel finishes.

Heading #15.1

1 Single Door #2030A

Prefunction 2034 to Women
2030

LH

Opening Description: 3' 0" x 8' 0" x 1 3/4 x WD Type D1 x HM Type 01

4	Butt Hinge	FBB179 4.5" x 4.5"		4	ST
1	Deadlock	48H-7R PATD CORMAX PATENTED KEYING	LH	606	BE
3	Silencer	1229A		GREY	TR
1	Mortise Cylinder	1EA-6A4 RP2		606	BE
1	Closer	ITS 9625 BRKTMD		606	DM
1	Kick Plate	K0050 8" x 34" B4E-HEAVY-KP CSK		606	TR
2	Door Pull-Frank Allart	1916B BTB MTG		SB.	VA01

Note: Specified Trimco floor stop model 2130 is not a valid number. Please confirm 1211 is acceptable.
Verify hinge & deadbolt finishes 606/US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass).

Heading #16

1 Single Door #2030C

Women 2030 from Toilet
Stall 2030

LHR

Opening Description: 2' 10 1/2" x 8' 0" x 1 3/4 x WD Type D1A x HMF Type 01A

2	Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
2	Butt Hinge	2060R 4.5" x 4.5"		4	ST
3	Silencer	1229A		GREY	TR
1	Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	LHR	AB	VA01
1	privacy indicator	0148 X T58 FRANK ALLART		SB	VA01
1	Overhead Stop	4023		US4	AB
1	1279 coat hook	1279CH			VA01
	Note: AB Finish				
1	Frank Allart lever with ind	7774 X 7846 IND ROSETTE		SB.	VA01

Note: Verify lock body face plate in AB finish is acceptable (a split finish is not possible on a lock body only). Advise which side of Indicator set 0148 x T58 is to have the AB finish and which side is to have the PN finish. ***VERY IMPORTANT: Advise what IND suffix on lever trim is meant to denote AND advise which sprung suffix is required SPG or SPGT***

Charleston Place Permit Package 3
364458

Heading #16-1

1 Single Door #2030B	Women 2030 from Storage 2030B	LHR
1 Single Door #2030D	Women 2030 to Toilet Stall 2030	LH
1 Single Door #2030E	Women 2030 to Toilet Stall 2030	LH
1 Single Door #2030F	Women 2030 to Toilet Stall 2030	LH
1 Single Door #2030G	Women 2030 to Toilet Stall 2030	LH
1 Single Door #2030J	Women 2030 to Toilet Stall 2030	RH
1 Single Door #2030K	Women 2030 to Toilet Stall 2030	RH
1 Single Door #2030L	Women 2030 to Toilet Stall 2030	RH

Opening Description: 2' 8" x 8' 0" x 1 3/4 x WD Type D1A x HMF Type 01A

16 Butt Hinge	FBB179 4.5" x 4.5"	4	ST
16 Butt Hinge	2060R 4.5" x 4.5"	4	ST
24 Silencer	1229A	GREY	TR
1 Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	LHR	AB VA01
4 Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	LH	AB VA01
3 Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	RH	AB VA01
8 privacy indicator	0148 X T58 FRANK ALLART	SB	VA01
8 Overhead Stop	4023	US4	AB
8 1279 coat hook	1279CH		VA01
Note: AB Finish			
8 Frank Allart lever with ind	7774 X 7846 IND ROSETTE	SB.	VA01

Note: Verify lock body face plate in AB finish is acceptable (a split finish is not possible on a lock body only). Advise which side of Indicator set 0148 x T58 is to have the AB finish and which side is to have the PN finish. ***VERY IMPORTANT: Advise what IND suffix on lever trim is meant to denote AND advise which sprung suffix is required SPG or SPGT***

Heading #16-2

1 Single Door #2030H

Women 2030 from Toilet
Stall 2030

RHR

Opening Description: 3' 0" x 8' 0" x 1 3/4 x WD Type D1A x HMF Type 01A

2	Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
2	Butt Hinge	2060R 4.5" x 4.5"		4	ST
3	Silencer	1229A		GREY	TR
1	Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	RHR	AB	VA01
1	privacy indicator	0148 X T58 FRANK ALLART		SB	VA01
1	Overhead Stop	4023		US4	AB
1	1279 coat hook	1279CH			VA01
	Note: AB Finish				
1	Frank Allart lever with ind	7774 X 7846 IND ROSETTE		SB.	VA01

Note: Verify lock body face plate in AB finish is acceptable (a split finish is not possible on a lock body only). Advise which side of Indicator set 0148 x T58 is to have the AB finish and which side is to have the PN finish. ***VERY IMPORTANT: Advise what IND suffix on lever trim is meant to denote AND advise which sprung suffix is required SPG or SPGT***

Heading #16.1

1 Single Door #2032D

Men 2032 from Toilet Stall
2032

RHR

Opening Description: 2' 10 1/2" x 8' 0" x 1 3/4 x WD Type D1A x HMF Type 01A

2	Butt Hinge	FBB179 4.5" x 4.5" NRP		26	ST
2	Butt Hinge	2060R 4.5" x 4.5"		26	ST
1	1279 coat hook	1279CH			VA01
	Note: AB Finish				
3	Silencer	1229A		GREY	TR
1	Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	RHR	AB	VA01
1	7774 x 7846	FRANK ALLART		625E	VA01
1	0148 x T58	FRANK ALLART IND		625E	VA01
1	Overhead Stop	4023		US26	AB

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). ***VERY IMPORTANT: Advise what IND suffix on lever trim is meant to denote AND advise which sprung suffix is required SPG or SPGT***

Charleston Place Permit Package 3
364458

Heading #16.1-1

1 Single Door #2032B	Men 2032 to Toilet Stall 2032	RH
1 Single Door #2032C	Men 2032 to Toilet Stall 2032	RH

Opening Description: 2' 8" x 8' 0" x 1 3/4 x WD Type D1A x HMF Type 01A

4 Butt Hinge	FBB179 4.5" x 4.5" NRP	26	ST
4 Butt Hinge	2060R 4.5" x 4.5"	26	ST
2 1279 coat hook	1279CH		VA01
Note: AB Finish			
6 Silencer	1229A	GREY	TR
2 Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	RH AB	VA01
2 7774 x 7846	FRANK ALLART	625E	VA01
2 0148 x T58	FRANK ALLART IND	625E	VA01
2 Overhead Stop	4023	US26	AB

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). ***VERY IMPORTANT: Advise what IND suffix on lever trim is meant to denote AND advise which sprung suffix is required SPG or SPGT***

Heading #16.1-2

1 Single Door #2032E

Men 2032 from Toilet Stall
2032

RHR

Opening Description: 3' 0" x 8' 0" x 1 3/4 x WD Type D1A x HMF Type 01A

2	Butt Hinge	FBB179 4.5" x 4.5" NRP		26	ST
2	Butt Hinge	2060R 4.5" x 4.5"		26	ST
1	1279 coat hook	1279CH			VA01
	Note: AB Finish				
3	Silencer	1229A		GREY	TR
1	Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	RHR	AB	VA01
1	0148 x T58	FRANK ALLART IND		625E	VA01
1	7774 x 7846	FRANK ALLART LEVER TRIM WITH IND		625E	VA01

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). ***VERY IMPORTANT: Advise what IND suffix on lever trim is meant to denote AND advise which sprung suffix is required SPG or SPGT***

Heading #17

1 Single Door #2019

Prefunction 2034 to Storage
2019

LH

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD Type D6 x HM Type 01

3	Butt Hinge	FBB179 4.5" x 4.5"		4	ST
1	Lock Body Only	8859 2"BS LOCK BODY ONLY	LH	AB	VA01
1	Construction Core	7190224			BE
1	Mortise Cylinder	1E-74 PATD CORMAX PATENTED KEYING		606	BE
3	Silencer	1229A		GREY	TR
1	Overhead Stop	4023		US4	AB
1	Frank Allart Lockset	7774 LEVER X 7846 ROSETTE SPRUNG		SB.	VA01

Note: Majority of these door are toilet stalls but doors 2019 and 2031 are utility closets that may require different hardware. All hardware is missing from set 17. Please advise on all. We used the second 16.1 set located directly after 17. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). ***VERY IMPORTANT: Confirm this trim is UNSPRUNG (all others denote SPRUNG and IND Suffix)***

Charleston Place Permit Package 3
364458

Heading #17-1

1 Single Door #2051A	Hampton 2051 from Storage 2051A	RHR
1 Single Door #2052A	Edmunds 2052 from Storage 2052A	RHR
1 Single Door #2052B	Edmunds 2052 from Storage 2052B	LHR
1 Single Door #2061D	Ashley Cpr 2061 from Storage 2061D	RHR
1 Single Door #2061E	Ashley Cpr 2061 from Storage 2061E	RHR
1 Single Door #2066A	N Meeting 1 2066 from Storage 2066A	RHR
1 Single Door #2066B	N Meeting 1 2066 from Storage 2066B	RHR
1 Single Door #2066C	N Meeting 1 2066 from Storage 2066C	LHR
1 Single Door #2066D	N Meeting 1 2066 from Storage 2066D	LHR
1 Single Door #2066E	N Meeting 1 2066 from Storage 2066E	LHR

Opening Description: 3' 0" x 7' 10" x 1 3/4 x WD Type D6 Type 01-WD
3' 0" x 7' 10" x 1 3/4 x WD Type D6 x HMF Type 01-WD
3' 0" x 7' 10" x 1 3/4 x WD Type D6 x HMF Type 02-WD

40 Butt Hinge	FBB179 4.5" x 4.5" NRP	4	ST
6 Lock Body Only	8859 2"BS LOCK BODY ONLY	RHR AB	VA01
4 Lock Body Only	8859 2"BS LOCK BODY ONLY	LHR AB	VA01
10 Construction Core	7190224		BE
10 Mortise Cylinder	1E-74 PATD CORMAX PATENTED KEYING	606	BE
30 Silencer	1229A	GREY	TR
10 Overhead Stop	4023	US4	AB
10 Frank Allart Lockset	7774 LEVER X 7846 ROSETTE SPRUNG	SB.	VA01

Note: Majority of these door are toilet stalls but doors 2019 and 2031 are utility closets that may require different hardware. All hardware is missing from set 17. Please advise on all. We used the second 16.1 set located directly after 17. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). ***VERY IMPORTANT: Confirm this trim is UNSPRUNG (all others denote SPRUNG and IND Suffix)***

Charleston Place Permit Package 3
364458

Heading #17-2

1 Single Door #2031 Men 2032 to Janitor 2031 RH
Opening Description: 3' 0" x 8' 0" x 1 3/4 x WD Type D1 x HM Type 01

4	Butt Hinge	FBB179 4.5" x 4.5"		26	ST
1	Lock Body Only	8859 2"BS LOCK BODY ONLY	RH	AB	VA01
1	Construction Core	7190224			BE
1	Frant Allart Trim Set	7774 LEVER X 7846 ROSETTE		AB	VA01
		UNSPRUNG/CONCL			
3	Silencer	1229A		GREY	TR
1	Mortise Cylinder	1E-74 PATD CORMAX PATENTED KEYING		625	BE
1	Overhead Stop	4024		US4	AB

Note: Majority of these door are toilet stalls but doors 2019 and 2031 are utility closets that may require different hardware. All hardware is missing from set 17. Please advise on all. We used the second 16.1 set located directly after 17. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). ***VERY IMPORTANT: Confirm this trim is UNSPRUNG (all others denote SPRUNG and IND Suffix)***

Heading #18

1 Single Door #2033

W Fountain 2034B to Family
R/R 2033

RH

Opening Description: 3' 0" x 8' 0" x 1 3/4 x WD Type D1 x HM Type 01

2	Butt Hinge	FBB179 4.5" x 4.5"		4	ST
2	Butt Hinge	2060R 4.5" x 4.5"		4	ST
3	Silencer	1229A		GREY	TR
1	Accurate Lock Privacy	8839. 2"BS LOCK BODY ONLY	RH	AB	VA01
1	privacy indicator	0148 X T58 FRANK ALLART		SB	VA01
1	Overhead Stop	4024		US4	AB
1	Frank Allart Lockset	7774 LEVER X 7846 ROSETTE SPRUNG		SB.	VA01

Note: *****VERY IMPORTANT: Confirm this trim is UNSPRUNG (all others denote SPRUNG and IND Suffix)*****
Verify all hardware item requirements for this door. ALL hardware was struck through in the set but no replacement items are denoted. Specified Trimco floor stop model 2130 at set 15.1 is not a valid number. Please confirm 1211 is acceptable.

Heading #19

1 Pair Doors #2034A

Walk-in 3036 from F&B Stor
3040

LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD Type D12 x HM Type 02

6	Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
1	Exit Device	5547WDC-L-BE x 376L-BE-WDC	LHR	US4	VO
1	Exit Device	5547WDC-L-BE x 376L-BE-WDC	RHR	US4	VO
2	Closer	EHD9016 AF90		689	BE
	Note: SNB				
2	Kick Plate	K0050 8" x 34" B4E-HEAVY-KP CSK		606	TR
2	Silencer	1229A		GREY	TR

Note: Closer is specified w/ 689 (aluminum) finish but all other hardware is 609 (antique brass). Please confirm this was intended. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). Specified Trimco floor stop model 2130 at sets 15.1, 18, 19 is not a valid number. Please confirm 1211 is acceptable.

Heading #19-1

1 Pair Doors #2018A

Prefunction 2034 from BOH
Corr 2018

LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD Type D12 x HM Type 02

6	Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
1	Exit Device	5547WDC-L-BE x 376L-BE-WDC	LHR	US4	VO
1	Exit Device	5547WDC-L-BE x 376L-BE-WDC	RHR	US4	VO
2	Closer	EHD9016 AF90		689	BE
	Note: SNB				
2	Kick Plate	K0050 8" x 34" B4E-HEAVY-KP CSK		606	TR
1	Frank Allart Lockset	7774 LEVER X 7846 ROSETTE SPRUNG		SB.	VA01
2	Silencer	1229A		GREY	TR

Note: Closer is specified w/ 689 (aluminum) finish but all other hardware is 609 (antique brass). Please confirm this was intended. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). Specified Trimco floor stop model 2130 at sets 15.1, 18, 19 is not a valid number. Please confirm 1211 is acceptable.

Charleston Place Permit Package 3
364458

Heading #19.1

1 Pair Doors #2063

Meeting Corr from Corr
2063

LHR\RHR

Opening Description: 2 - 3' 0" x 7' 3" x 1 3/4 x WD Type D12 TO x HM Type 02 x 45 Min

6	Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
1	Exit Device	3RO FL 2214 X 4914A 36" 8'0" LBR SNB (4)	LHR	606	PR
1	Exit Device	3RO FL 2214 X 4914A 36" 8'0" LBR SNB (4)	RHR	606	PR
2	Electromagnetic Door Holder	2100		S2	AB
2	Closer	EHD9016 AF90		606	BE
2	Gasketing	5050 B-25 25'			NA

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass).

Heading #20

1 Other Door #**3033**

Existing Corr from IDF 3033

Note: All existing hardware to remain

Charleston Place Permit Package 3
364458

Heading #21

1 Single Door #2052C	Prefunction 2034 to Edmunds 2052	LH
1 Single Door #2051	Prefunction 2034 to Hampton 2051	RH
1 Single Door #2052	Prefunction 2034 to Edmunds 2052	LH

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD Type D6 x HMF Type 01

9 Butt Hinge	FBB179 4.5" x 4.5"		4	ST
3 Hotel Guestroom Cardlock(By Others)	VINGCARD SIGNATURE HOTEL LOCK			VA01
3 Construction Core	7190224			BE
3 Mortise Cylinder	1E-74 PATD CORMAX PATENTED KEYING		606	BE
2 Concealed Closer	3133 HBUMP	LH	633	LC
1 Concealed Closer	3133 HBUMP	RH	633	LC
3 2130 FRANK ALLART STOP	2130 BLACK BUMPER		606	VA01
3 Frank Allart Lockset	7774 LEVER X 7846 ROSETTE SPRUNG		SB.	VA01
9 Silencer	1229A		GREY	TR

Note: ***VERY IMPORTANT: Advise which sprung suffix is required SPG or SPGT*** Lock body finish is spec'd 606 (satin brass) but lever trims are spec'd AB (antique brass). Please confirm this was intended. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass).

Charleston Place Permit Package 3
364458

Heading #21-1

1 Single Door #2061A	Ashley Cpr 2061 from Storage 2061A	LHR
1 Single Door #2061B	Ashley Cpr 2061 from Storage 2061B	LHR
1 Single Door #2061C	Ashley Cpr 2061 from Storage 2061C	RHR

Opening Description: 3' 0" x 7' 10" x 1 3/4 x WD Type D6 x HMF Type 01-WD

12 Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
1 Lock Body Only	8859 2"BS LOCK BODY ONLY	RHR	AB	VA01
2 Lock Body Only	8859 2"BS LOCK BODY ONLY	LHR	AB	VA01
3 Construction Core	7190224			BE
3 Mortise Cylinder	1E-74 PATD CORMAX PATENTED KEYING		606	BE
3 Overhead Stop	4023		US4	AB
3 Frank Allart Lockset	7774 LEVER X 7846 ROSETTE SPRUNG		SB.	VA01
9 Silencer	1229A		GREY	TR

Note: ***VERY IMPORTANT: Advise which sprung suffix is required SPG or SPGT*** Lock body finish is spec'd 606 (satin brass) but lever trims are spec'd AB (antique brass). Please confirm this was intended. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass).

Charleston Place Permit Package 3
364458

Heading #21.1

1 Single Door #2062	Corr 2063 from Ashley Cpr 2061	RHR
1 Single Door #31	Corr 2068 from N Meeting 1 2066	LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD Type D6 x HM Type 01 x 45 Min
3' 0" x 7' 0" x 1 3/4 x WD Type D6 x HMF Type 01 x 45 Min

6 Butt Hinge	FBB179 4.5" x 4.5" NRP	4	ST
2 Exit Device	55EO	US4	VO
2 Closer	ITS 9625 BRKTMD INV	606	DM
2 Closer	ITS 9625 BRKTMD	606	DM
2 Kick Plate	K0050 8" x 34" B4E-HEAVY-KP CSK	609	TR
2 2130 FRANK ALLART STOP	2130 BLACK BUMPER	606	VA01
2 Gasketing	5050 C-17 17'		NA
2 Auto Door Bottom	683 36"		NA

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). Verify what exit device trim is required (none specified).

Heading #23

1	Pair Doors #2061	Mezzanine from Ashley Cpr 2061	LHR\RHR
1	Pair Doors #2066	Mezzanine from N Meeting 1 2066	LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD Type D12 x HM Type 02

12	Butt Hinge	FBB179 4.5" x 4.5" NRP	4	ST
4	Shear Aligning Magnalock	SAM	US32D	SN
8	1917 BTN Frank Allart	1917	SB.	VA01
4	Closer	ITS 9625 BRKTMD	606	DM
4	Kick Plate	K0050 8" x 34" B4E-HEAVY-KP CSK	609	TR
2	Gasketing	5050 B-25 25'		NA
4	Auto Door Bottom	683 36"		NA

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). Advise what inactive leaf hardware and exit trim type is intended for this set (none specified).

Charleston Place Permit Package 3
364458

Heading #24

1 Double Egress Door #2068

Corr 2068 to/from
Mezzanine

DELHR

Opening Description: 2 - 3' 0" x 7' 3" x 1 3/4 x WD Type D12 x HM Type 02-DE x 45 Min

6	Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
2	Exit Device	3RO FL 2701 LBR Spec. Bar Height	LHR	606	PR
	Properties: Spec. Bar Height=7'3"				
2	Electromagnetic Door Holder	2100		S2	AB
2	Closer	EHD9016 AF90		606	BE
2	Gasketing	5050 B-25 25'			NA

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass).

Heading #25

1 Single Door #ST2-2A

Stair 2 ST 2-2 from BOH Corr
2018

RHR

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD Type D6 x HM Type 01 x 90 Min

3	Butt Hinge	FBB179 4.5" x 4.5" NRP		4	ST
1	Exit Device	3RO FL 2114 X 4914A	RHR	606	PR
1	Closer	EHD9016 AF90		606	BE
1	Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		606	TR
1	Wall Bumper	1270WV		606	TR
1	Gasketing	5050 B-25 25'			NA

Note: Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 638 or US5 (antique brass).

Charleston Place Permit Package 3
364458

Heading #02.

1 Single Door #1030

BOH Corr 1026 to Receiving
1030

LH

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D3 x HM Type 04

3	Butt Hinge	FBB179 4.5" x 4.5" NRP		26D	ST
1	Lockset	45H-7D15H PATD CORMAX PATENTED KEYING	LH	626	BE
1	Construction Core	7190224			BE
1	Closer	EHD9016 AF90		689	BE
	Note: SNB				
1	Kick Plate	K0050 10" x 34" B4E-HEAVY-KP CSK		630	TR
3	Silencer	1229A		GREY	TR

Heading #29

1 Pair Doors #X2010A				LHR\RHR
1 Pair Doors #X2010B				LHR\RHR
1 Pair Doors #X2011A				LHR\RHR
1 Pair Doors #X2012A				LHR\RHR
1 Pair Doors #X2013C				LHR\RHR
1 Pair Doors #X2013B				LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD Type D1 x HM

6 Pivot	0117	LH	US4	AB
6 Pivot	0117	RH	US4	AB
6 Pivot	019	RH	US4	AB
6 Pivot	019	LH	US4	AB
24 1917 BTN Frank Allart	1917		SB.	VA01
6 Concealed Closer	3033 REGARM	RH	BRASS	LC
6 Concealed Closer	3033 REGARM	LH	BRASS	LC
12 354 WSP set White with grey	354WSP 84		WH	VA01
6 Astragal	143 SA 84"			NA
12 Smoke Seal	S88 W 20'			PE
12 Auto Door Bottom	411 ASL 36"			PE

Heading #30

1 Pair Doors #X2010C

LHR\RHR

1 Pair Doors #X2010D

LHR\RHR

Opening Description: 2 - 4' 0" x 8' 0" x 1 3/4 x WD Type D1 x HM

2 Pivot	0117	LH	US4	AB
2 Pivot	0117	RH	US4	AB
4 Pivot	019	RH	US4	AB
4 Pivot	019	LH	US4	AB
4 1917 BTN Frank Allart	1917		SB.	VA01
2 Concealed Closer	3033 REGARM	RH	BRASS	LC
2 Concealed Closer	3033 REGARM	LH	BRASS	LC
2 Gasketing	5050 B-25 25'			NA
4 Astragal	143 SA 96"			NA
4 Auto Door Bottom	683 48"			NA

Charleston Place Permit Package 3
364458

Heading #38

1 Pair Doors #X2013A

LHR\RHR

1 Pair Doors #X2014C

LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD Type D1 x HM

2 Pivot	0117	LH	US4	AB
2 Pivot	0117	RH	US4	AB
2 Pivot	019	RH	US4	AB
2 Pivot	019	LH	US4	AB
4 1917 BTN Frank Allart	1917		SB.	VA01
4 Closer	ITS 9613 BRKTMD		606	DM
2 Astragal	143 SA 84"			NA
2 Gasketing	5050 B-20 20'			NA
4 Auto Door Bottom	683 36"			NA

Heading #33

- 1 Pair Doors #X2010E LHR\RHR
- 1 Pair Doors #X2010F LHR\RHR
- 1 Pair Doors #X2014A LHR\RHR
- 1 Pair Doors #X2014B LHR\RHR

Opening Description: 2 - 3' 0" x 7' 0" x 1 3/4 x WD Type D1 x HM

8	Continuous Hinge	A500 83-1/8"	US32D	AB
8	Door Pull	1191-2	630	TR
8	1917 BTN Frank Allart	1917	SB.	VA01
8	Closer	EHD9016 FHP90	696	BE
4	Astragal	143 SA 84"		NA
4	Gasketing	5050 B-20 20'		NA
8	Auto Door Bottom	683 36"		NA

Heading #35

1 Single Door #X2011B

RHR

Opening Description: 3' 0" x 7' 0" x 1¾" x HM Type D1 x HMF

1 Continuous Hinge	664HD UL 83"	AL	ST
1 Door Pull	1191-2	630	TR
1 1917 BTN Frank Allart	1917	SB.	VA01
1 Closer	EHD9016 FHP90	696	BE
1 Gasketing	5050 B-17 17'		NA
1 Auto Door Bottom	683 36"		NA

Heading #36

1 Single Door #X2012B

LHR

Opening Description: 4' 0" x 7' 0" x 1¾" x HM x HMF

1 Continuous Hinge	664HD UL 83"	AL	ST
1 Door Pull	1191-2	630	TR
1 1917 BTN Frank Allart	1917	SB.	VA01
1 Closer	EHD9016 FHP90	696	BE
1 Gasketing	5050 B-17 17'		NA
1 Auto Door Bottom	683 36"		NA

Charleston Place Permit Package 3
364458

Heading #17-3

1 Single Door #2049

Corr 2050 from IDF 2049

LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD Type EXIST x HMF Type EXIST

4	Butt Hinge	FBB179 4.5" x 4.5"		4	ST
1	Lock Body Only	8859 2"BS LOCK BODY ONLY	LHR	AB	VA01
1	Construction Core	7190224			BE
1	Mortise Cylinder	1E-74 PATD CORMAX PATENTED KEYING		606	BE
3	Silencer	1229A		GREY	TR
1	Frank Allart Lockset	7774 LEVER X 7846 ROSETTE SPRUNG		SB.	VA01

Note: Majority of these door are toilet stalls but doors 2019 and 2031 are utility closets that may require different hardware. All hardware is missing from set 17. Please advise on all. We used the second 16.1 set located directly after 17. Verify hinge finish US4 (clear satin brass) is acceptable. Specified mfg does not offer a 609 or US5 finish (antique brass). ***VERY IMPORTANT: Confirm this trim is UNSPRUNG (all others denote SPRUNG and IND Suffix)***

Heading #TEMP

- 1 Single Door #2049T LHR
- 1 Single Door #2052T LHR

Opening Description: 3' 0" x 7' 0" x 1 3/4 x WD

6 Butt Hinge	FBB179 4.5" x 4.5" NRP	4	ST
2 en-fed.p.trr.044	OFFICE FED	4	VA01

Products By Opening

Qty	Product Description	Openings(Qty) Where Used
42	H001 - Butt Hinge FBB179 4.5" x 4.5" NRP 26D	1030(3), 1031(6), 1034A(3), 1034C(3), 1034D(3), 1034E(3), 2022B(3), 2025B(3), 2026B(6), 1077(6), 3019E(3)
113	H004 - Butt Hinge FBB179 4.5" x 4.5" NRP 4	2004C(3), 2018A(6), 2030C(2), 2030H(2), 2034A(6), 2049T(3), 2052T(3), 2050(3), 2051A(4), 2052A(4), 2052B(4), 2061(6), 2061A(4), 2061B(4), 2061C(4), 2061D(4), 2061E(4), 2062(3), 2063(6), 2066(6), 2066A(4), 2066B(4), 2066C(4), 2066D(4), 2066E(4), 31(3), 2068(6), ST2-2A(3)
36	H008 - Butt Hinge FBB179 4.5" x 4.5" 26D	1028(3), 1029(3), 1034B(6), 1042(3), 1045(3), 1046(3), 2024(6), 2027(3), 2028(3), 2029(3)
8	H010 - Butt Hinge FBB179 4.5" x 4.5" NRP 26	2032B(2), 2032C(2), 2032D(2), 2032E(2)
38	H011 - Butt Hinge FBB179 4.5" x 4.5" 4	2019(3), 2030A(4), 2030B(2), 2030D(2), 2030E(2), 2030F(2), 2030G(2), 2030J(2), 2030K(2), 2030L(2), 2033(2), 2049(4), 2052C(3), 2051(3), 2052(3)
14	H013 - Butt Hinge FBB179 4.5" x 4.5" 26	2031(4), 2032A(4), 2053A(3), 2055A(3)
2	H016 - Continuous Hinge 664HD UL 83" AL	X2011B, X2012B
8	H020 - Continuous Hinge A500 83-1/8" US32D	X2010E(2), X2010F(2), X2014A(2), X2014B(2)
28	H012 - Butt Hinge 2060R 4.5" x 4.5" 4	2004C(3), 2030B(2), 2030C(2), 2030D(2), 2030E(2), 2030F(2), 2030G(2), 2030H(2), 2030J(2), 2030K(2), 2030L(2), 2033(2), 2050(3)
8	H014 - Butt Hinge 2060R 4.5" x 4.5" 26	2032B(2), 2032C(2), 2032D(2), 2032E(2)
10	P001 - Pivot 0117 LH US4	X2010A, X2010B, X2011A, X2012A, X2013C, X2013B, X2010C, X2010D, X2013A, X2014C
10	P001 - Pivot 0117 RH US4	X2010A, X2010B, X2011A, X2012A, X2013C, X2013B, X2010C, X2010D, X2013A, X2014C
12	P003 - Pivot 019 RH US4	X2010A, X2010B, X2011A, X2012A, X2013C, X2013B, X2010C(2), X2010D(2), X2013A, X2014C
12	P003 - Pivot 019 LH US4	X2010A, X2010B, X2011A, X2012A, X2013C, X2013B, X2010C(2), X2010D(2), X2013A, X2014C
6	M002 - Manual Flushbolt 3917-12 626	1031(2), 2026B(2), 1077(2)
2	L011 - Deadlock 48H-7R PATD CORMAX PATENTED KEYING RH 606	2032A, 2053A
2	L011 - Deadlock 48H-7R PATD CORMAX PATENTED KEYING LH 606	2030A, 2055A
2	L008 - Lockset 45H-7D15H PATD CORMAX PATENTED KEYING LHR 626	2029, 3019E
2	L008 - Lockset 45H-7D15H PATD CORMAX PATENTED KEYING LH 626	1030, 1045

Charleston Place Permit Package 3
364458

Qty	Product Description	Openings(Qty) Where Used
4	L008 - Lockset 45H-7D15H PATD CORMAX PATENTED KEYING RH 626	1028, 1031, 2026B, 1077
3	L008 - Lockset 45H-7D15H PATD CORMAX PATENTED KEYING RHR 626	1034D, 1034E, 2025B
2	L009 - Lockset 45H-7AB15H PATD CORMAX PATENTED KEYING RH 626	1029, 2027
2	L009 - Lockset 45H-7AB15H PATD CORMAX PATENTED KEYING LH 626	1042, 2028
1	L010 - Passage Set 45H-0N15H LH 626	1046
1	L013 - Lock Body Only 8859 2"BS LOCK BODY ONLY LH AB	2019
1	L013 - Lock Body Only 8859 2"BS LOCK BODY ONLY RH AB	2031
7	L013 - Lock Body Only 8859 2"BS LOCK BODY ONLY RHR AB	2051A, 2052A, 2061C, 2061D, 2061E, 2066A, 2066B
7	L013 - Lock Body Only 8859 2"BS LOCK BODY ONLY LHR AB	2049, 2052B, 2061A, 2061B, 2066C, 2066D, 2066E
2	L017 - Accurate Lock Privacy 8839. 2"BS LOCK BODY ONLY LHR AB	2030B, 2030C
4	L017 - Accurate Lock Privacy 8839. 2"BS LOCK BODY ONLY LH AB	2030D, 2030E, 2030F, 2030G
6	L017 - Accurate Lock Privacy 8839. 2"BS LOCK BODY ONLY RH AB	2030J, 2030K, 2030L, 2032B, 2032C, 2033
3	L017 - Accurate Lock Privacy 8839. 2"BS LOCK BODY ONLY RHR AB	2030H, 2032D, 2032E
3	L029 - Hotel Guestroom Cardlock VINGCARD SIGNATURE HOTEL LOCK	2052C, 2051, 2052
11	L024 - privacy indicator 0148 X T58 FRANK ALLART SB	2030B, 2030C, 2030D, 2030E, 2030F, 2030G, 2030H, 2030J, 2030K, 2030L, 2033
3	L025 - 7774 x 7846 FRANK ALLART 625E	2032B, 2032C, 2032D
4	L026 - 0148 x T58 FRANK ALLART IND 625E	2032B, 2032C, 2032D, 2032E
1	L027 - 7774 x 7846 FRANK ALLART LEVER TRIM WITH IND 625E	2032E
2	L035 - en-fed.p.trr.044 OFFICE FED 4	2049T, 2052T
3	E003 - Exit Device 3RO FL 2214 X 4914A 36" 8'0" LBR SNB (4) LHR 606	2004C, 2050, 2063
3	E003 - Exit Device 3RO FL 2214 X 4914A 36" 8'0" LBR SNB (4) RHR 606	2004C, 2050, 2063
1	E004 - Exit Device 3RO 2103 X 4903A 36" SNB (2) RHR 630	2022B
1	E006 - Exit Device 3RO FL 2114 X 4914A RHR 606	ST2-2A
2	E007 - Exit Device 3RO 2108 X 4908A 36" LHR 630	1034A, 1034C

Charleston Place Permit Package 3
364458

Qty	Product Description	Openings(Qty) Where Used
1	E008 - Exit Device 3RO 2214 X 4914A 36" 7'0" LBR LHR 606	1034B
1	E008 - Exit Device 3RO 2214 X 4914A 36" 7'0" LBR RHR 606	1034B
2	E013 - Exit Device 3RO FL 2701 LBR Spec. Bar Height LHR 606	2068(2)
2	E014 - Exit Device 5547WDC-L-BE x 376L-BE-WDC LHR US4	2018A, 2034A
2	E014 - Exit Device 5547WDC-L-BE x 376L-BE-WDC RHR US4	2018A, 2034A
2	E015 - Exit Device 55EO US4	2062, 31
38	A003 - Construction Core 7190224	1030, 1026C, 1028, 1029, 1031, 1034A, 1034C, 1034D, 1034E, 1042, 1045, 2019, 2022B, 2025B, 2026B, 2027, 2028, 2029, 2031, 2049, 2052C, 2051, 2051A, 2052, 2052A, 2052B, 2061A, 2061B, 2061C, 2061D, 2061E, 2066A, 2066B, 2066C, 2066D, 2066E, 1077, 3019E
4	A006 - Rim Cylinder 12E-72 PATD CORMAX PATENTED KEYING 626	1026C, 1034A, 1034C, 2022B
18	A007 - Mortise Cylinder 1E-74 PATD CORMAX PATENTED KEYING 606	2019, 2049, 2052C, 2051, 2051A, 2052, 2052A, 2052B, 2061A, 2061B, 2061C, 2061D, 2061E, 2066A, 2066B, 2066C, 2066D, 2066E
2	A009 - Mortise Cylinder 1EA-6A4 RP2 606	2030A, 2055A
3	A010 - Mortise Cylinder 1EA-6A4 RP2 625	2032A, 2053A, 2055A
1	A011 - Mortise Cylinder 1E-74 PATD CORMAX PATENTED KEYING 625	2031
2	F002 - Push/Pull Plate 1894-4 630	2024(2)
3	F080 - Door Pull-Frank Allart 1916B BTB MTG PN	2032A, 2053A, 2055A
10	F257 - Door Pull 1191-2 630	X2011B, X2012B, X2010E(2), X2010F(2), X2014A(2), X2014B(2)
6	I001 - Electromagnetic Door Holder 2100 S2	2004C, 2050, 2063(2), 2068(2)
4	I002 - Shear Aligning Magnalock SAM US32D	2061(2), 2066(2)
50	M018 - 1917 BTN Frank Allart 1917 SB.	X2010A(4), X2010B(4), X2011A(4), X2012A(4), X2013C(4), X2013B(4), X2010C(2), X2010D(2), X2013A(2), X2014C(2), X2011B, X2012B, X2010E(2), X2010F(2), X2014A(2), X2014B(2), 2061(4), 2066(4)
2	M003 - Coordinator 3094D BLACK	2004C, 2050
10	C001 - Closer EHD9016 AF90 689	1030, 1028, 1045, 1046, 2018A(2), 2029, 2034A(2), 3019E
7	C002 - Closer EHD9016 SDS90 689	1034A, 1034B(2), 1034C, 2022B, 2024(2)
2	C004 - Closer ITS 9625 BRKTMD INV 606	2062, 31
9	C005 - Closer EHD9016 AF90 606	2004C(2), 2050(2), 2063(2), 2068(2), ST2-2A
2	C006 - Concealed Closer 3133 HBUMP LH 633	2052C, 2052

Charleston Place Permit Package 3
364458

Qty	Product Description	Openings(Qty) Where Used
1	C006 - Concealed Closer 3133 HBUMP RH 633	2051
10	C007 - Closer ITS 9625 BRKTMD 606	2030A, 2032A, 2053A, 2055A, 2061(2), 2062, 2066(2), 31
10	C012 - Closer EHD9016 FHP90 696	X2011B, X2012B, X2010E(2), X2010F(2), X2014A(2), X2014B(2)
8	C013 - Concealed Closer 3033 REGARM RH BRASS	X2010A, X2010B, X2011A, X2012A, X2013C, X2013B, X2010C, X2010D
8	C013 - Concealed Closer 3033 REGARM LH BRASS	X2010A, X2010B, X2011A, X2012A, X2013C, X2013B, X2010C, X2010D
4	C014 - Closer ITS 9613 BRKTMD 606	X2013A(2), X2014C(2)
24	S005 - Overhead Stop 4023 US4	2019, 2030B, 2030C, 2030D, 2030E, 2030F, 2030G, 2030H, 2030J, 2030K, 2030L, 2051A, 2052A, 2052B, 2061A, 2061B, 2061C, 2061D, 2061E, 2066A, 2066B, 2066C, 2066D, 2066E
3	S006 - Overhead Stop 4023 US26	2032B, 2032C, 2032D
2	S009 - Overhead Stop 4024 US4	2031, 2033
9	F001 - Kick Plate K0050 10" x 34" B4E-HEAVY-KP CSK 630	1030, 1028, 1034A, 1034C, 1045, 1046, 2022B, 2025B, 2029
6	F006 - Kick Plate K0050 8" x 34" B4E-HEAVY-KP CSK 609	2061(2), 2062, 2066(2), 31
1	F007 - Kick Plate K0050 10" x 46" B4E-HEAVY-KP CSK 630	3019E
11	F079 - Kick Plate K0050 10" x 35" B4E-HEAVY-KP CSK 630	1031(2), 1034B(2), 2024(2), 2025B, 2026B(2), 1077(2)
2	F130 - Kick Plate K0050 10" x 20" B4E-HEAVY-KP CSK 630	1034D, 1034E
2	F131 - Kick Plate K0050 10" x 21" B4E-HEAVY-KP CSK 630	1034D, 1034E
7	F187 - Kick Plate K0050 8" x 34" B4E-HEAVY-KP CSK 606	2018A(2), 2030A, 2032A, 2034A(2), 2053A
1	F188 - Kick Plate K0050 10" x 34" B4E-HEAVY-KP CSK 606	ST2-2A
17	S001 - Wall Bumper 1270WV 630	1029, 1031(2), 1034A, 1034C, 1034D, 1034E, 1042, 2024(2), 2025B, 2026B(2), 2027, 2028, 1077(2)
1	S004 - Wall Bumper 1270WV 606	ST2-2A
5	F203 - 2130 FRANK ALLART STOP 2130 BLACK BUMPER 606	2052C, 2051, 2052, 2062, 31
14	M012 - 1279 coat hook 1279CH	2030B, 2030C, 2030D, 2030E, 2030F, 2030G, 2030H, 2030J, 2030K, 2030L, 2032B, 2032C, 2032D, 2032E
5	M015 - Door Pull-Frank Allart 1916B BTB MTG SB.	2030A(2), 2032A, 2053A, 2055A
10	M016 - Frank Allart lever with ind 7774 X 7846 IND ROSETTE SB.	2030B, 2030C, 2030D, 2030E, 2030F, 2030G, 2030H, 2030J, 2030K, 2030L

Charleston Place Permit Package 3
364458

Qty	Product Description	Openings(Qty) Where Used
20	M017 - Frank Allart Lockset 7774 LEVER X 7846 ROSETTE SPRUNG SB.	2018A, 2019, 2033, 2049, 2052C, 2051, 2051A, 2052, 2052A, 2052B, 2061A, 2061B, 2061C, 2061D, 2061E, 2066A, 2066B, 2066C, 2066D, 2066E
12	M022 - 354 WSP set White with grey 354WSP 84 WH	X2010A(2), X2010B(2), X2011A(2), X2012A(2), X2013C(2), X2013B(2)
11	W001 - Gasketing 5050 B-25 25'	X2010C, X2010D, 2004C, 2050, 2061, 2063(2), 2066, 2068(2), ST2-2A
3	W002 - Gasketing 5050 C-17 17'	2022B, 2062, 31
2	W013 - Gasketing 5050 B-17 17'	X2011B, X2012B
12	W016 - Astragal 143 SA 84"	X2010A, X2010B, X2011A, X2012A, X2013C, X2013B, X2013A, X2014C, X2010E, X2010F, X2014A, X2014B
6	W017 - Gasketing 5050 B-20 20'	X2013A, X2014C, X2010E, X2010F, X2014A, X2014B
4	W018 - Astragal 143 SA 96"	X2010C(2), X2010D(2)
12	W022 - Smoke Seal S88 W 20'	X2010A(2), X2010B(2), X2011A(2), X2012A(2), X2013C(2), X2013B(2)
20	W005 - Auto Door Bottom 683 36"	X2013A(2), X2014C(2), X2011B, X2012B, X2010E(2), X2010F(2), X2014A(2), X2014B(2), 2061(2), 2062, 2066(2), 31
4	W019 - Auto Door Bottom 683 48"	X2010C(2), X2010D(2)
12	W021 - Auto Door Bottom 411 ASL 36"	X2010A(2), X2010B(2), X2011A(2), X2012A(2), X2013C(2), X2013B(2)
173	M001 - Silencer 1229A GREY	1030(3), 1028(3), 1029(3), 1031(2), 1034A(3), 1034B(2), 1034C(3), 1034D(3), 1034E(3), 1042(3), 1045(3), 1046(3), 2018A(2), 2019(3), 2024(2), 2025B(3), 2026B(2), 2027(3), 2028(3), 2029(3), 2030A(3), 2030B(3), 2030C(3), 2030D(3), 2030E(3), 2030F(3), 2030G(3), 2030H(3), 2030J(3), 2030K(3), 2030L(3), 2031(3), 2032A(3), 2032B(3), 2032C(3), 2032D(3), 2032E(3), 2033(3), 2034A(2), 2049(3), 2052C(3), 2051(3), 2051A(3), 2052(3), 2052A(3), 2052B(3), 2053A(3), 2055A(3), 2061A(3), 2061B(3), 2061C(3), 2061D(3), 2061E(3), 2066A(3), 2066B(3), 2066C(3), 2066D(3), 2066E(3), 1077(2), 3019E(3)
1	R005 - Frant Allart Trim Set 7774 LEVER X 7846 ROSETTE UNSPRUNG/CONCL AB	2031